



Product Service


# CERTIFICATE

No. Z2 115385 0007 Rev. 00

**Holder of Certificate:** **Shenzhen Megarevo Technology Co., Ltd.**

4th Floor, Block 2  
INVT Guangming Technology Building  
Shutianpu Community, Matian Neighborhood  
Guangming New District  
518106 Shenzhen  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:**

**Converter  
(Hybrid Solar Inverter)**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64290213068301

**Valid until:** 2027-09-29

**Date,** 2022-09-30

( Billy Qiu )

# CERTIFICATE

No. Z2 115385 0007 Rev. 00

**Model(s): R6KH3, R8KH3, R10KH3, R12KH3, R15KH3**

## Parameters:

Model	R6KH3	R8KH3	R10KH3	R12KH3	R15KH3
<b>Battery terminal parameters</b>					
Rated battery DC voltage	200 Vd.c.	250 Vd.c.	300 Vd.c.	350 Vd.c.	400 Vd.c.
Battery DC voltage range	125-600 Vd.c.				
Max charging / discharging current	50 Ad.c.				
Battery type	Lithium-ion				
Maximum charge/discharge power	15000 W				
<b>PV terminal parameters</b>					
Max. Input Power	9000 W	12000 W	15000 W	18000 W	22500 W
Maximum DC input voltage	1000 Vd.c.				
MPPT Range	180~850 Vd.c.				
MPPT Range (full load)	250~850 Vd.c.	330~850 Vd.c.	430~850 Vd.c.	510~850 Vd.c.	620~850 Vd.c.
Max. Input Current	2*13 Ad.c.				
Isc PV	2*16 Ad.c.				2*25 Ad.c.
<b>Grid terminal parameters</b>					
Rated output Power	6000 W	8000 W	10000 W	12000 W	15000 W
Maximum continuous output apparent power	6600 VA	8800 VA	11000 VA	13200 VA	16500 VA
Max. AC output current	9.5 Aa.c.	12.7 Aa.c.	15.9 Aa.c.	19.1 Aa.c.	23.8 Aa.c.
Maximum continuous input apparent power	13200 VA	17600 VA	22000 VA	26400 VA	33000 VA
Max. AC input current	19 Aa.c.	25.5 Aa.c.	31.9 Aa.c.	38.2 Aa.c.	47.6 Aa.c.
Rated AC voltage	230/400 Va.c., 3W+N+PE				
Rated AC frequency	50/60 Hz				
Power factor	0.9lagging to 0.9leading				
<b>Backup terminal parameters</b>					
Rated apparent power	6000 VA	8000 VA	10000 VA	12000 VA	15000 VA
Maximum continuous output apparent power	6600 VA	8800 VA	11000 VA	13200 VA	16500 VA
Max. AC current	9.5 Aa.c.	12.7 Aa.c.	15.9 Aa.c.	19.1 Aa.c.	23.8 Aa.c.
Rated AC voltage	230/400 Va.c., 3W+N+PE				
Rated AC frequency	50/60 Hz				
<b>General</b>					
Protection class	I				
Ingress protection	IP 65				
Overvoltage Category	II(PV/Battery), III(Mains)				
Temperature	-25 °C ~ +60 °C, derating above 45 °C				
Altitude	≤2000				



# CERTIFICATE

No. Z2 115385 0007 Rev. 00

**Tested  
according to:**

IEC 62109-1:2010  
EN 62109-1:2010  
IEC 62109-2:2011  
EN 62109-2:2011